




TEST REPORT

Sample Receipt No/Date :	58537-58538/Dt.05.07.2023
Invoice Details :	6770/Dt.05.07.2023
Customer Name and Address :	St.Mary's Public School (CBSE), Leigh Bazaar, Arisipalayam, Salem-636009.
Test Commenced on :	05.07.2023
Test Completed on :	06.07.2023
Test Report Date :	08.07.2023
SAMPLE DETAILS FURNISHED BY CUSTOMER	
Source :	RO
Location :	RO water @ St.Mary's Public Secondary School(CBSE).
Sample drawn by/Date :	Customer/Dt.05.07.2023
Quantity Received :	2 litres
Sample Container :	Plastic
Condition of the Sample :	Good Condition
The test result of sample received is as follows.	

S.No	I. CHEMICAL EXAMINATION	Method of Testing	Unit	Sample No. 58537 Result	Specification as per IS 10500 : 2012
					Permissible Limit
1	pH at 25°C	IS 3025 Part 11-1983	-	6.52	6.5-8.5
2	Total Alkalinity as CaCO ₃	IS 3025-Part 23-1986	mg/L	40	600
3	Total Hardness as CaCO ₃	IS 3025 Part 21-2009	mg/L	28	600
4	Chloride as Cl	IS 3025-Part 32-1988	mg/L	12	1000
5	Sulphate as SO ₄	IS 3025-Part 24-1986	mg/L	4	400
6	Nitrate as NO ₃	APHA 23rd Edition 2017- 4500 -NO2 B	mg/L	0	45
7	Fluoride as F	APHA 23rd Edition 2017 - 4500- F-D	mg/L	0.2	1.5


.....End of the report.....


Authorised Signatory,
TWAD Board, R.W.S,
Salem.

Note:

1. The test results relate only to the tested sample.
2. The test report shall not be reproduced anywhere except in full and in the same format without the permission of the laboratory.


PRINCIPAL
St. Mary's Public School (CBSE),
Arisipalayam, SALEM-636 009.


CORRESPONDENT
St. Mary's Public School (CBSE),
Arisipalayam, SALEM-636 009.